

Electrical Transient Analyzer Program

Short-Circuit Analysis

IEC 60909 Standard

3-Phase, LG, LL, & LLG Fault Currents

	Swing	V-Control	Load	Total			
Number of Buses:	2	0	89	91			
	XFMR2	XFMR3	Reactor	Line/Cable/ Busway	Impedance	Tie PD	Total
Number of Branches:	37	0	0	46	2	3	88
	Synchronous Generator	Power Grid	Synchronous Motor	Induction Machines	Lumped Load	Inverter	Total
Number of Machines:	1	1	1	0	0	44	47

Project:

Location:

Contract:

Engineer:

Filename:

MINI-GRID (IMG) 6.45MWp/10MWh

JAJI, KADUNA

A. ADEFEMI

AES RENEWABLES

ETAP

24.0.1N

Study Case: SC

Page:

Date:

SN:

Revision:

Config.:

2

28-09-2026

DNDLYIR

Base

Normal

Adjustments

Tolerance	Apply Adjustments	Individual /Global	Percent
Transformer Impedance:	Yes	Individual	
Reactor Impedance:	Yes	Individual	
Overload Heater Resistance:	No		
Transmission Line Length:	No		
Cable / Busway Length:	No		

Temperature Correction	Apply Adjustments	Individual /Global	Degree C
Transmission Line Resistance:	Yes	Individual	
Cable / Busway Resistance:	Yes	Individual	

Bus					Initial Voltage	
ID	Type	Nom. kV	Base kV	Sub-sys	%Mag.	Ang.
Bus111	Load	0.415	0.456	2	100.00	-60.00
Bus112	Load	0.415	0.456	2	100.00	-60.00
Bus113	Load	0.800	0.808	2	100.00	0.00
Bus114	Load	0.800	0.808	2	100.00	0.00
Bus115	Load	0.415	0.445	2	100.00	-60.00
MV_BUS	Load	11.000	11.803	2	105.00	-30.00
Cable3~	Load	11.000	11.000	1	100.00	0.00

91 Buses Total

All voltages reported by ETAP are in % of bus Nominal kV.
Base kV values of buses are calculated and used internally by ETAP.

Line/Cable/Busway Input Data

ohms or siemens per 1000 m per Conductor (Cable) or per Phase (Line/Busway)

Line/Cable/Busway												
ID	Library	Size	Length		#/Phase	T (°C)	R1	X1	Y1	R0	X0	Y0
			Adj. (m)	% Tol.								
Cable3	HNALS1	500	5.0	0.0	1	75	0.0749853	0.2006089	0.0001829	0.0754025	0.7152569	0.0001829
Line1		111	165.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line2		111	254.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line3		111	393.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line4		111	259.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line5		111	765.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line6		111	50.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line7		111	2600.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line8		111	3600.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line9		111	3300.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line10		111	1818.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line11		111	360.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line12		111	65.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line13		111	609.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line14		111	822.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line15		111	200.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line16		111	449.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line17		111	1660.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line18		111	2070.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line19		111	609.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line20		111	300.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line21		111	684.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line22		111	555.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line23		111	1100.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line24		111	491.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line25		111	200.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line26		111	335.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line27		111	149.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line28		111	119.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line29		111	300.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line30		111	90.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line31		111	150.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line32		111	332.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line33		111	200.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line34		111	100.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016

ohms or siemens per 1000 m per Conductor (Cable) or per Phase (Line/Busway)

Line/Cable/Busway												
ID	Library	Size	Length		#/Phase	T (°C)	R1	X1	Y1	R0	X0	Y0
			Adj. (m)	% Tol.								
Line35		111	132.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line36		111	132.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line37		111	100.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line38		111	142.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line39		111	100.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line40		111	700.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line41		111	250.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line42		111	1450.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line43		111	230.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line44		111	777.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016
Line45		111	1244.0	0.0	1	75	0.3140408	0.2910776	0.0000041	0.6379963	0.9624727	0.0000016

Line / Cable / Busway resistances are listed at the specified temperatures.

2-Winding Transformer Input Data

Transformer		Rating				Z Variation			% Tap Setting		Adjusted	Phase Shift	
ID	MVA	Prim. kV	Sec. kV	% Z	X/R	+ 5%	- 5%	% Tol.	Prim.	Sec.	% Z	Type	Angle
500KVA PRIMARY	0.500	11.000	0.415	5.00	3.50	0	0	0	5.000	2.500	5.00	Dyn	-30.00
AIRTEL BIRNIN YERO	0.050	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
ALHAJI BALA	0.300	11.000	0.415	4.00	1.50	0	0	0	0	0	4.00	Dyn	30.00
Aux TR	0.250	11.000	0.415	7.50	3.50	0	0	0	0	0	7.50	Dyn	30.00
BABBAN GIDA	0.300	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00
BIRNIN YERO 1	0.300	11.000	0.415	4.00	1.50	0	0	0	0	0	4.00	Dyn	30.00
BIRNIN YERO 1 RELIEF	0.300	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
BIRNIN YERO 2	0.300	11.000	0.415	4.00	1.50	0	0	0	0	0	4.00	Dyn	30.00
DANDAMI	0.100	11.000	0.415	5.00	3.50	0	0	0	0	2.500	5.00	Dyn	30.00
FIRST GATE	0.500	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00
FOUNDATION	0.300	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
FRSC	0.100	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
HAYIN SADAUKI	0.300	11.000	0.415	4.00	1.50	0	0	0	0	0	4.00	Dyn	30.00
HAYIN UMMA	0.300	11.000	0.415	4.00	1.50	0	0	0	0	0	4.00	Dyn	30.00
HYDRAF WATER	0.300	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
IHS BOOSTER STATION	0.050	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00
JAFI	0.500	11.000	0.415	4.00	1.50	0	0	0	0	0	4.00	Dyn	30.00
KAHO VILLAGE	0.300	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00
KAMPANIN PATE RELIEF	0.300	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00
KAN ZAURE	0.200	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00
KANGADA	0.500	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00
KARGO DAM	0.300	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00
MTN BIRNIN YERO	0.050	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
POLICE DIVISION HG	0.200	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
PROPOSED KWARAU VILLAGE R	0.200	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
PULLO FARM	0.100	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
SHEHU KARAWU	0.300	11.000	0.415	4.00	1.50	0	0	0	0	0	4.00	Dyn	30.00
SKYPET	0.200	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
STS	6.600	11.000	0.800	7.50	3.50	0	0	0	5.000	0	7.50	Dyn	-30.00
STS 2	6.600	11.000	0.800	8.35	13.00	0	0	0	6.250	0	8.35	Dyn	-30.00
T2	5.000	11.000	0.415	7.15	8.50	0	0	0	7.300	0	7.15	Dyn	-30.00
T10	0.100	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00
TSOHON BIRNIN YERO	0.300	11.000	0.415	4.00	1.50	0	0	0	0	0	4.00	Dyn	30.00
U/ RIMI	0.200	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00

Transformer		Rating				Z Variation			% Tap Setting		Adjusted	Phase Shift	
ID	MVA	Prim. kV	Sec. kV	% Z	X/R	+ 5%	- 5%	% Tol.	Prim.	Sec.	% Z	Type	Angle
URWA	0.050	11.000	0.415	4.00	1.50	0	0	0	0	2.500	4.00	Dyn	30.00
ZARIA ROAD 1 500KVA	0.500	11.000	0.415	4.00	1.50	0	0	0	5.000	2.500	4.00	Dyn	30.00
ZARIA ROAD 2	0.300	11.000	0.415	5.00	3.50	0	0	0	0	0	5.00	Dyn	30.00

2-Winding Transformer Grounding Input Data

Transformer	Rating			Grounding								
				Conn.	Primary				Secondary			
ID	MVA	Prim. kV	Sec. kV	Type	Type	kV	Amp	ohm	Type	kV	Amp	ohm
500KVA PRIMARY	0.500	11.000	0.415	D/Y					Solid			
AIRTEL BIRNIN YERO	0.050	11.000	0.415	D/Y					Solid			
ALHAJI BALA	0.300	11.000	0.415	D/Y					Solid			
Aux TR	0.250	11.000	0.415	D/Y					Solid			
BABBAN GIDA	0.300	11.000	0.415	D/Y					Solid			
BIRNIN YERO 1	0.300	11.000	0.415	D/Y					Solid			
BIRNIN YERO 1 RELIEF	0.300	11.000	0.415	D/Y					Solid			
BIRNIN YERO 2	0.300	11.000	0.415	D/Y					Solid			
DANDAMI	0.100	11.000	0.415	D/Y					Solid			
FIRST GATE	0.500	11.000	0.415	D/Y					Solid			
FOUNDATION	0.300	11.000	0.415	D/Y					Solid			
FRSC	0.100	11.000	0.415	D/Y					Solid			
HAYIN SADAUKI	0.300	11.000	0.415	D/Y					Solid			
HAYIN UMMA	0.300	11.000	0.415	D/Y					Solid			
HYDRAF WATER	0.300	11.000	0.415	D/Y					Solid			
IHS BOOSTER STATION	0.050	11.000	0.415	D/Y					Solid			
JAFI	0.500	11.000	0.415	D/Y					Solid			
KAHO VILLAGE	0.300	11.000	0.415	D/Y					Solid			
KAMPANIN PATE RELIEF	0.300	11.000	0.415	D/Y					Solid			
KAN ZAURE	0.200	11.000	0.415	D/Y					Solid			
KANGADA	0.500	11.000	0.415	D/Y					Solid			
KARGO DAM	0.300	11.000	0.415	D/Y					Solid			
MTN BIRNIN YERO	0.050	11.000	0.415	D/Y					Solid			
POLICE DIVISION HG	0.200	11.000	0.415	D/Y					Solid			
PROPOSED KWARAU VILLAGE R	0.200	11.000	0.415	D/Y					Solid			
PULLO FARM	0.100	11.000	0.415	D/Y					Solid			

2-Winding Transformer Grounding Input Data

Transformer		Rating		Grounding								
				Conn.	Primary				Secondary			
ID	MVA	Prim. kV	Sec. kV	Type	Type	kV	Amp	ohm	Type	kV	Amp	ohm
SHEHU KARAWU	0.300	11.000	0.415	D/Y					Solid			
SKYPET	0.200	11.000	0.415	D/Y					Solid			
STS	6.600	11.000	0.800	D/Y					Solid			
STS 2	6.600	11.000	0.800	D/Y					Solid			
T2	5.000	11.000	0.415	D/Y					Solid			
T10	0.100	11.000	0.415	D/Y					Solid			
TSOHON BIRNIN YERO	0.300	11.000	0.415	D/Y					Solid			
U/ RIMI	0.200	11.000	0.415	D/Y					Solid			
URWA	0.050	11.000	0.415	D/Y					Solid			
ZARIA ROAD 1 500KVA	0.500	11.000	0.415	D/Y					Solid			
ZARIA ROAD 2	0.300	11.000	0.415	D/Y					Solid			

Impedance Input Data

Immedance		Positive Sequence Impedanc			Zero Sequence Impedance			Unit
ID		R	X	Y	R0	X0	Y0	
Z4		0.001	0.001	0	0.001	0.001	0	% in 0.800 kV base and 100.0 MVA base
Z5		0.001	0.001	0.001	0.001	0.001	0.001	% in 0.415 kV base and 100.0 MVA base

Project:	MINI-GRID (IMG) 6.45MWp/10MWh	ETAP	Page:	11
Location:	JAJI, KADUNA	24.0.1N	Date:	28-09-2026
Contract:			SN:	DNDLYIR
Engineer:	A. ADEFEMI	Study Case: SC	Revision:	Base
Filename:	AES RENEWABLES		Config.:	Normal

Branch Connections

CKT/Branch		Connected Bus ID		% Impedance, Pos. Seq., 100 MVAb			
ID	Type	From Bus	To Bus	R	X	Z	Y
500KVA PRIMARY	2W XFMR	Bus26	Bus87	255.05	892.69	928.41	
AIRTEL BIRNIN YERO	2W XFMR	Bus64	Bus107	3769.42	5654.13	6795.42	
ALHAJI BALA	2W XFMR	Bus74	Bus108	628.24	942.36	1132.57	
Aux TR	2W XFMR	MV_BUS	Bus115	684.43	2395.51	2491.37	
BABBAN GIDA	2W XFMR	Bus38	Bus83	385.57	1349.50	1403.50	
BIRNIN YERO 1	2W XFMR	Bus56	Bus96	628.24	942.36	1132.57	
BIRNIN YERO 1 RELIEF	2W XFMR	Bus47	Bus97	628.24	942.36	1132.57	
BIRNIN YERO 2	2W XFMR	Bus60	Bus100	628.24	942.36	1132.57	
DANDAMI	2W XFMR	Bus54	Bus94	1156.71	4048.49	4210.50	
FIRST GATE	2W XFMR	Bus40	Bus90	231.34	809.70	842.10	
FOUNDATION	2W XFMR	Bus76	Bus112	628.24	942.36	1132.57	
FRSC	2W XFMR	Bus72	Bus109	1884.71	2827.07	3397.71	
HAYIN SADAUKI	2W XFMR	Bus62	Bus99	628.24	942.36	1132.57	
HAYIN UMMA	2W XFMR	Bus57	Bus103	628.24	942.36	1132.57	
HYDRAF WATER	2W XFMR	Bus79	Bus110	628.24	942.36	1132.57	
IHS BOOSTER STATION	2W XFMR	Bus32	Bus86	2313.42	8096.98	8420.99	
JAFI	2W XFMR	Bus68	Bus104	376.94	565.41	679.54	
KAHO VILLAGE	2W XFMR	Bus36	Bus82	385.57	1349.50	1403.50	
KAMPANIN PATE RELIEF	2W XFMR	Bus41	Bus92	385.57	1349.50	1403.50	
KAN ZAURE	2W XFMR	Bus52	Bus91	578.36	2024.25	2105.25	
KANGADA	2W XFMR	Bus39	Bus88	231.34	809.70	842.10	
KARGO DAM	2W XFMR	Bus35	Bus84	385.57	1349.50	1403.50	
MTN BIRNIN YER0	2W XFMR	Bus63	Bus102	3769.42	5654.13	6795.42	
POLICE DIVISION HG	2W XFMR	Bus65	Bus106	942.36	1413.53	1698.86	
PROPOSED KWARAU VILLAGE R	2W XFMR	Bus59	Bus98	942.36	1413.53	1698.86	
PULLO FARM	2W XFMR	Bus78	Bus111	1884.71	2827.07	3397.71	
SHEHU KARAWU	2W XFMR	Bus61	Bus101	628.24	942.36	1132.57	
SKYPET	2W XFMR	Bus67	Bus105	942.36	1413.53	1698.86	
STS	2W XFMR	MV_BUS	Bus8	28.58	100.04	104.04	
STS 2	2W XFMR	MV_BUS	Bus114	9.04	117.51	117.85	
T2	2W XFMR	MV_BUS	Bus3	15.99	135.88	136.81	
T10	2W XFMR	Bus43	Bus89	1156.71	4048.49	4210.50	
TSOHON BIRNIN YERO	2W XFMR	Bus49	Bus93	628.24	942.36	1132.57	
U/ RIMI	2W XFMR	Bus34	Bus85	578.36	2024.25	2105.25	
URWA	2W XFMR	Bus55	Bus95	3769.42	5654.13	6795.42	
ZARIA ROAD 1 500KVA	2W XFMR	Bus29	Bus81	415.58	623.37	749.20	

Project:	MINI-GRID (IMG) 6.45MWp/10MWh	ETAP	Page:	12
Location:	JAJI, KADUNA	24.0.1N	Date:	28-09-2026
Contract:			SN:	DNDLYIR
Engineer:	A. ADEFEMI	Study Case: SC	Revision:	Base
Filename:	AES RENEWABLES		Config.:	Normal

CKT/Branch		Connected Bus ID		% Impedance, Pos. Seq., 100 MVAb			
ID	Type	From Bus	To Bus	R	X	Z	Y
ZARIA ROAD 2	2W XFMR	Bus30	Bus45	385.57	1349.50	1403.50	
Cable3	Cable	Bus15	Cable3~	0.03	0.08	0.09	0.0001107
Z4	Impedance	Bus114	Bus113	0.00	0.00	0.00	
Z5	Impedance	Bus115	Bus9	0.00	0.00	0.00	0.0011513
Line1	Line	Bus2	Bus26	3.72	3.45	5.07	0.0000943
Line2	Line	Bus26	Bus27	5.73	5.31	7.81	0.0001452
Line3	Line	Bus28	Bus30	8.86	8.21	12.08	0.0002246
Line4	Line	Bus27	Bus29	5.84	5.41	7.96	0.0001480
Line5	Line	Bus27	Bus32	17.24	15.98	23.51	0.0004372
Line6	Line	Bus32	Bus34	1.13	1.04	1.54	0.0000286
Line7	Line	Bus34	Bus35	58.61	54.32	79.91	0.0014858
Line8	Line	Bus32	Bus36	81.15	75.22	110.65	0.0020573
Line9	Line	Bus37	Bus38	74.39	68.95	101.43	0.0018859
Line10	Line	Bus27	Bus39	40.98	37.99	55.88	0.0010390
Line11	Line	Bus40	Bus41	8.12	7.52	11.07	0.0002057
Line12	Line	Bus39	Bus43	1.47	1.36	2.00	0.0000371
Line13	Line	Bus39	Bus40	13.73	12.72	18.72	0.0003480
Line14	Line	Bus48	Bus49	18.53	17.17	25.27	0.0004698
Line15	Line	Bus46	Bus64	4.51	4.18	6.15	0.0001143
Line16	Line	Bus56	Bus57	10.12	9.38	13.80	0.0002566
Line17	Line	Bus41	Bus48	37.42	34.68	51.02	0.0009487
Line18	Line	Bus48	Bus42	46.66	43.25	63.62	0.0011830
Line19	Line	Bus56	Bus51	13.73	12.72	18.72	0.0003480
Line20	Line	Bus42	Bus52	6.76	6.27	9.22	0.0001714
Line21	Line	Bus42	Bus54	15.42	14.29	21.02	0.0003909
Line22	Line	Bus54	Bus55	12.51	11.60	17.06	0.0003172
Line23	Line	Bus55	Bus56	24.80	22.98	33.81	0.0006286
Line24	Line	Bus56	Bus47	11.07	10.26	15.09	0.0002806
Line25	Line	Bus47	Bus59	4.51	4.18	6.15	0.0001143
Line26	Line	Bus56	Bus60	7.55	7.00	10.30	0.0001914
Line27	Line	Bus60	Bus61	3.36	3.11	4.58	0.0000852
Line28	Line	Bus51	Bus62	2.68	2.49	3.66	0.0000680
Line29	Line	Bus51	Bus50	6.76	6.27	9.22	0.0001714
Line30	Line	Bus50	Bus63	2.03	1.88	2.77	0.0000514
Line31	Line	Bus50	Bus46	3.38	3.13	4.61	0.0000857
Line32	Line	Bus46	Bus65	7.48	6.94	10.20	0.0001897
Line33	Line	Bus50	Bus66	4.51	4.18	6.15	0.0001143
Line34	Line	Bus66	Bus67	2.25	2.09	3.07	0.0000571
Line35	Line	Bus66	Bus68	2.98	2.76	4.06	0.0000754

CKT/Branch		Connected Bus ID		% Impedance, Pos. Seq., 100 MVAb			
ID	Type	From Bus	To Bus	R	X	Z	Y
Line36	Line	Bus66	Bus70	2.98	2.76	4.06	0.0000754
Line37	Line	Bus70	Bus72	2.25	2.09	3.07	0.0000571
Line38	Line	Bus70	Bus73	3.20	2.97	4.36	0.0000812
Line39	Line	Bus73	Bus74	2.25	2.09	3.07	0.0000571
Line40	Line	Bus73	Bus75	15.78	14.63	21.52	0.0004000
Line41	Line	Bus75	Bus76	5.64	5.22	7.68	0.0001429
Line42	Line	Bus75	Bus77	32.69	30.30	44.57	0.0008286
Line43	Line	Bus77	Bus78	5.18	4.81	7.07	0.0001314
Line44	Line	Bus80	Bus79	17.52	16.23	23.88	0.0004440
Line45	Line	Bus77	Bus80	28.04	25.99	38.24	0.0007109
CB2	Tie Breakr	MV_BUS	Bus2				
CB32	Tie Breakr	Bus36	Bus37				
CB33	Tie Breakr	Bus29	Bus28				

Project:	MINI-GRID (IMG) 6.45MWp/10MWh	ETAP	Page:	14
Location:	JAJI, KADUNA	24.0.1N	Date:	28-09-2026
Contract:			SN:	DNDLYIR
Engineer:	A. ADEFEMI	Study Case: SC	Revision:	Base
Filename:	AES RENEWABLES		Config.:	Normal

Power Grid Input Data

Power Grid ID	Connected Bus ID	Rating		% Impedance 100 MVA Base			Grounding Type
		MVASC	kV	R	X"	R/X"	
U1	Bus15	100.000	11.000	9.95037	99.50372	0.10	Wye - Solid

Total Connected Power Grids (= 1): 100.000 MVA

Synchronous Generator Input Data

Synchronous Generator							% Impedance in Machine Base							Excitation		
							Rating			Xd"			Grounding			
ID	Type	MVA	kV	RPM	% PF	R	Adj.	Tol.	R/X	Xd, sat	Conn.	Type	Amp	Type		
Gen1	Steam Turbo	2.500	0.415	1500	90.00	1.000	19.00	0.0	0.05	155.00	Wye	Solid	0.00	Turbine 130%		

Total Connected Synchronous Generators (= 1.00) : 2.500 MVA

Project:	MINI-GRID (IMG) 6.45MWp/10MWh	ETAP	Page:	15
Location:	JAJI, KADUNA	24.0.1N	Date:	28-09-2026
Contract:			SN:	DNDLYIR
Engineer:	A. ADEFEMI	Study Case: SC	Revision:	Base
Filename:	AES RENEWABLES		Config.:	Normal

Synchronous Motor Input Data

Synchronous Motor			Connected Bus	Rating				
ID	Type	Qty	ID	HP/kW	kVA	kV	Amp	%PF
Syn1	Motor	1	Bus87	7.00	8.22	0.415	11.44	85.69

Total Connected Synchronous Motors (= 1): 8.2 kVA

Synchronous Motor			% Impedance in Motor Base				Grounding			Exciter Type
ID	Type	Qty	Xd"			R/X	Conn.	Type	Amp	
			R	Adj.	Tol.					
Syn1	Motor	1	8.089	16.67	0.0	0.49	Wye	Open		Turbine 130%

Project:	MINI-GRID (IMG) 6.45MWp/10MWh	ETAP	Page:	16
Location:	JAJI, KADUNA	24.0.1N	Date:	28-09-2026
Contract:			SN:	DNDLYIR
Engineer:	A. ADEFEMI	Study Case: SC	Revision:	Base
Filename:	AES RENEWABLES		Config.:	Normal

UPS Input Data

ID	AC Rating								DC Rating			Bypass Switch	% Impedance Equipment Base	
	kVA	kV		FLA		% EFF	% PF	R					X	
		Input	Output	Input	Output									
UPS1	20.00	0.415	0.415	30.92	27.82	90.00	85.00	49.51	362.441	150.0	No	66.67	0.00	

SHORT-CIRCUIT REPORT

Fault at bus: Bus8
Nominal kV = 0.800
Voltage c Factor = 1.05 (User-Defined)

Contribution		3-Phase Fault		Line-To-Ground Fault					Positive & Zero Sequence Impedances Looking into "From Bus"			
From Bus ID	To Bus ID	% V From Bus	kA Symm. rms	% Voltage at From Bus			kA Symm. rms		% Impedance on 100 MVA base			
				Va	Vb	Vc	Ia	3I0	R1	X1	R0	X0
Bus8	Total	0.00	12.788	0.00	144.62	148.29	17.632	17.632	8.46E+001	9.69E+002	2.86E+001	1.00E+002
MV_BUS	Bus8	16.46	10.411	92.46	81.38	170.03	13.839	17.632 *	4.79E+001	6.95E+002	2.86E+001	1.00E+002
PVA1	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA2	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA3	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA4	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA5	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA6	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA7	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA8	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA9	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA10	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA11	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA12	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA13	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA14	Bus8	0.00	0.119	0.00	144.62	148.29	0.236	0.000				
PVA15	Bus8	0.00	0.119	0.00	144.62	148.29	0.239	0.000				
PVA16	Bus8	0.00	0.119	0.00	144.62	148.29	0.239	0.000				
PVA17	Bus8	0.00	0.119	0.00	144.62	148.29	0.239	0.000				
PVA18	Bus8	0.00	0.119	0.00	144.62	148.29	0.239	0.000				
PVA20	Bus8	0.00	0.119	0.00	144.62	148.29	0.239	0.000				
PVA21	Bus8	0.00	0.119	0.00	144.62	148.29	0.239	0.000				
Bus115	MV_BUS	16.46	0.000	150.88	21.88	144.36	0.000	0.000				
Bus114	MV_BUS	21.02	0.229	24.10	141.45	144.32	0.238	0.000	1.17E+003	1.58E+003		
Bus3	MV_BUS	28.94	0.491	32.81	121.10	133.66	0.145	0.000	4.68E+002	7.87E+002		
Bus26	Bus2	16.46	0.002	92.46	81.38	170.03	0.001	0.000	3.08E+004	2.07E+005		

(Cont.)

Fault at bus:

Bus8

Nominal kV

= 0.800

Voltage c Factor

= 1.05 (User-Defined)

Contribution		3-Phase Fault		Line-To-Ground Fault					Positive & Zero Sequence Impedances Looking into "From Bus"			
From Bus	To Bus	% V	kA	% Voltage at From Bus			kA Symm. rms		% Impedance on 100 MVA base			
ID	ID	From Bus	Symm. rms	Va	Vb	Vc	Ia	3I0	R1	X1	R0	X0
		3-Phase		L-G		L-L		L-L-G				
Initial Symmetrical Current (kA, rms)		:	12.788	17.632		10.998		22.795				
Peak Current (kA), Method C		:	26.267	36.216		22.591		46.822				
Breaking Current (kA, rms, symm)		:		17.632		10.998		22.795				
Steady State Current (kA, rms)		:	12.514	17.632		10.998		22.795				

Indicates a fault current contribution from a three-winding transformer.

* Indicates a zero sequence fault current contribution (3I0) from a grounded Delta-Y transformer.

Fault at bus: **Bus40**

Nominal kV = 11.000

Voltage c Factor = 1.10 (User-Defined)

Contribution		3-Phase Fault		Line-To-Ground Fault					Positive & Zero Sequence Impedances Looking into "From Bus"			
From Bus ID	To Bus ID	% V From Bus	kA Symm. rms	% Voltage at From Bus			kA Symm. rms		% Impedance on 100 MVA base			
				Va	Vb	Vc	Ia	3I0	R1	X1	R0	X0
Bus40	Total	0.00	1.023	0.00	190.53	190.53	0.000	0.000	1.20E+002	9.29E+002		
Bus41	Bus40	0.00	0.000	0.00	190.53	190.53	0.000	0.000				
Bus39	Bus40	4.20	1.023	0.00	190.53	190.53	0.000	0.000	4.80E+001	4.88E+002		
Bus90	Bus40	0.00	0.000	110.00	110.00	110.00	0.000	0.000				
Bus48	Bus41	0.00	0.000	0.00	190.53	190.53	0.000	0.000				
Bus92	Bus41	0.00	0.000	110.00	110.00	110.00	0.000	0.000				
Bus27	Bus39	16.74	1.023	0.00	190.53	190.53	0.000	0.000	3.42E+001	4.75E+002		
Bus43	Bus39	4.20	0.000	0.00	190.53	190.53	0.000	0.000				
Bus88	Bus39	4.20	0.000	110.00	110.00	110.00	0.000	0.000				
		3-Phase		L-G		L-L		L-L-G				
Initial Symmetrical Current (kA, rms)		:	1.023	0.000		0.741		0.741				
Peak Current (kA), Method C		:	1.966	0.000		1.424		1.424				
Breaking Current (kA, rms, symm)		:		0.000		0.741		0.741				
Steady State Current (kA, rms)		:	1.003	0.000		0.741		0.741				

Indicates a fault current contribution from a three-winding transformer.

* Indicates a zero sequence fault current contribution (3I0) from a grounded Delta-Y transformer.

Fault at bus: Bus70

Nominal kV = 11.000

Voltage c Factor = 1.10 (User-Defined)

Contribution		3-Phase Fault		Line-To-Ground Fault					Positive & Zero Sequence Impedances Looking into "From Bus"			
From Bus ID	To Bus ID	% V From Bus	kA Symm. rms	% Voltage at From Bus			kA Symm. rms		% Impedance on 100 MVA base			
				Va	Vb	Vc	Ia	3I0	R1	X1	R0	X0
Bus70	Total	0.00	0.875	0.00	190.53	190.53	0.000	0.000	2.93E+002	1.09E+003		
Bus66	Bus70	0.78	0.875	0.00	190.53	190.53	0.000	0.000	3.52E+002	4.52E+002		
Bus72	Bus70	0.00	0.000	0.00	190.53	190.53	0.000	0.000				
Bus73	Bus70	0.00	0.000	0.00	190.53	190.53	0.000	0.000				
Bus50	Bus66	1.96	0.875	0.00	190.53	190.53	0.000	0.000	3.49E+002	4.50E+002		
Bus67	Bus66	0.78	0.000	0.00	190.53	190.53	0.000	0.000				
Bus68	Bus66	0.78	0.000	0.00	190.53	190.53	0.000	0.000				
Bus109	Bus72	0.00	0.000	112.75	112.75	112.75	0.000	0.000				
Bus74	Bus73	0.00	0.000	0.00	190.53	190.53	0.000	0.000				
Bus75	Bus73	0.00	0.000	0.00	190.53	190.53	0.000	0.000				
		3-Phase		L-G		L-L		L-L-G				
Initial Symmetrical Current (kA, rms)		:		0.875		0.000		0.560		0.560		
Peak Current (kA), Method C		:		1.507		0.000		0.965		0.965		
Breaking Current (kA, rms, symm)		:				0.000		0.560		0.560		
Steady State Current (kA, rms)		:		0.873		0.000		0.560		0.560		

Indicates a fault current contribution from a three-winding transformer.

* Indicates a zero sequence fault current contribution (3I0) from a grounded Delta- Y transformer.

Fault at bus: Bus110

Nominal kV = 0.415

Voltage c Factor = 1.05 (User-Defined)

Contribution		3-Phase Fault		Line-To-Ground Fault					Positive & Zero Sequence Impedances Looking into "From Bus"			
From Bus ID	To Bus ID	% V From Bus	kA Symm. rms	% Voltage at From Bus			kA Symm. rms		% Impedance on 100 MVA base			
				Va	Vb	Vc	Ia	3I0	R1	X1	R0	X0
Bus110	Total	0.00	7.492	0.00	116.15	123.07	7.790	7.790	1.02E+003	2.12E+003	6.28E+002	9.42E+002
Bus79	Bus110	71.97	7.492	86.54	127.69	95.21	7.790	7.790 *	1.49E+003	6.10E+002	6.28E+002	9.42E+002
Bus80	Bus79	73.45	0.290	86.99	127.69	96.01	0.174	0.000	9.69E+002	1.16E+003		
Initial Symmetrical Current (kA, rms)		3-Phase		L-G		L-L		L-L-G				
			7.492	7.790		5.712		8.329				
Peak Current (kA), Method C			12.017	12.495		9.162		13.360				
Breaking Current (kA, rms, symm)				7.790		5.712		8.329				
Steady State Current (kA, rms)			7.506	7.790		5.712		8.329				

Indicates a fault current contribution from a three-winding transformer.

* Indicates a zero sequence fault current contribution (3I0) from a grounded Delta- Y transformer.

Fault at bus:

Nominal kV

Voltage c Factor

Bus113

= 0.800

= 1.05 (User-Defined)

Contribution		3-Phase Fault		Line-To-Ground Fault					Positive & Zero Sequence Impedances Looking into "From Bus"			
From Bus ID	To Bus ID	% V From Bus	kA Symm. rms	% Voltage at From Bus			kA Symm. rms		% Impedance on 100 MVA base			
				Va	Vb	Vc	Ia	3I0	R1	X1	R0	X0
Bus113	Total	0.00	13.275	0.00	143.60	142.74	17.241	17.241	6.50E+001	9.87E+002	9.04E+000	1.18E+002
Bus114	Bus113	0.00	11.227	0.00	143.60	142.74	14.033	17.241	2.95E+001	6.61E+002	9.04E+000	1.18E+002
PCS 1	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 2	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 3	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 4	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 5	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 6	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 7	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 8	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 9	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 10	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 11	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 12	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 13	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 14	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 15	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 16	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 17	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 18	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 19	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 20	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 21	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 22	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 23	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
PCS 24	Bus113	0.00	0.085	0.00	143.60	142.74	0.160	0.000				
MV_BUS	Bus114	19.87	11.227	88.94	85.41	169.00	14.033	17.241 *	2.95E+001	6.61E+002	9.04E+000	1.18E+002

Project:	MINI-GRID (IMG) 6.45MWp/10MWh	ETAP	Page:	23
Location:	JAJI, KADUNA	24.0.1N	Date:	28-09-2026
Contract:			SN:	DNDLYIR
Engineer:	A. ADEFEMI	Study Case: SC	Revision:	Base
Filename:	AES RENEWABLES		Config.:	Normal

(Cont.)

Fault at bus: **Bus113**
Nominal kV = 0.800
Voltage c Factor = 1.05 (User-Defined)

Contribution		3-Phase Fault		Line-To-Ground Fault					Positive & Zero Sequence Impedances Looking into "From Bus"			
From Bus	To Bus	% V	kA	% Voltage at From Bus			kA Symm. rms		% Impedance on 100 MVA base			
ID	ID	From Bus	Symm. rms	Va	Vb	Vc	Ia	3I0	R1	X1	R0	X0
		3-Phase		L-G		L-L		L-L-G				
Initial Symmetrical Current (kA, rms)	:	13.275		17.241		10.873		22.709				
Peak Current (kA), Method C	:	27.548		35.777		22.562		47.123				
Breaking Current (kA, rms, symm)	:			17.241		10.873		22.709				
Steady State Current (kA, rms)	:	13.018		17.241		10.873		22.709				

Indicates a fault current contribution from a three-winding transformer.
* Indicates a zero sequence fault current contribution (3I0) from a grounded Delta-Y transformer.

Fault at bus: MV_BUS

Nominal kV = 11.000

Voltage c Factor = 1.10 (User-Defined)

Contribution		3-Phase Fault		Line-To-Ground Fault					Positive & Zero Sequence Impedances Looking into "From Bus"			
From Bus ID	To Bus ID	% V From Bus	kA Symm. rms	% Voltage at From Bus			kA Symm. rms		% Impedance on 100 MVA base			
				Va	Vb	Vc	Ia	3I0	R1	X1	R0	X0
MV_BUS	Total	0.00	0.916	0.00	190.53	190.53	0.000	0.000	5.60E+001	8.69E+002		
Bus115	MV_BUS	0.00	0.000	110.00	110.00	110.00	0.000	0.000				
Bus8	MV_BUS	4.02	0.185	104.76	104.76	104.76	0.000	0.000	2.47E-004	2.71E+003		
Bus114	MV_BUS	3.80	0.156	103.53	103.53	103.53	0.000	0.000	2.95E-004	3.21E+003		
Bus3	MV_BUS	16.04	0.573	102.52	102.52	102.52	0.000	0.000	5.48E+001	8.73E+002		
Bus26	Bus2	0.00	0.003	0.00	190.53	190.53	0.000	0.000	8.69E+004	1.79E+005		
Bus9	Bus115	0.00	0.000	110.00	110.00	110.00	0.000	0.000				
PVA1	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA2	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA3	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA4	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA5	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA6	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA7	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA8	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA9	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA10	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA11	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA12	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA13	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA14	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA15	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA16	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA17	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA18	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA20	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
PVA21	Bus8	4.02	0.133	104.76	104.76	104.76	0.224	0.000				
Bus113	Bus114	3.80	2.284	103.53	103.53	103.53	0.000	0.000	1.59E+003	2.66E+003		
Gen1	Bus3	102.52	16.308	102.52	102.52	102.52	0.000	0.000	3.88E+001	7.37E+002	3.88E+001	2.72E+002
Bus27	Bus26	0.00	0.000	0.00	190.53	190.53	0.000	0.000				
Bus87	Bus26	0.50	0.003	107.38	107.38	107.38	0.000	0.000	8.69E+004	1.79E+005		

Project:	MINI-GRID (IMG) 6.45MWp/10MWh	ETAP	Page:	25
Location:	JAJI, KADUNA	24.0.1N	Date:	28-09-2026
Contract:			SN:	DNDLYIR
Engineer:	A. ADEFEMI	Study Case: SC	Revision:	Base
Filename:	AES RENEWABLES		Config.:	Normal

(Cont.)

Fault at bus: MV_BUS
Nominal kV = 11.000
Voltage c Factor = 1.10 (User-Defined)

Contribution		3-Phase Fault		Line-To-Ground Fault					Positive & Zero Sequence Impedances Looking into "From Bus"			
From Bus	To Bus	% V	kA	% Voltage at From Bus			kA Symm. rms		% Impedance on 100 MVA base			
ID	ID	From Bus	Symm. rms	Va	Vb	Vc	Ia	3I0	R1	X1	R0	X0

		3-Phase	L-G	L-L	L-L-G
Initial Symmetrical Current (kA, rms)	:	0.916	0.000	0.830	0.830
Peak Current (kA), Method C	:	1.830	0.000	1.657	1.657
Breaking Current (kA, rms, symm)	:		0.000	0.830	0.830
Steady State Current (kA, rms)	:	0.559	0.000	0.830	0.830

Indicates a fault current contribution from a three-winding transformer.
* Indicates a zero sequence fault current contribution (3I0) from a grounded Delta- Y transformer.

Short-Circuit Summary Report

3-Phase, LG, LL, LLG Fault Currents

Bus		3-Phase Fault			Line-to-Ground Fault				Line-to-Line Fault				*Line-to-Line-to-Ground			
ID	kV	I"k	ip	Ik	I"k	ip	Ib	Ik	I"k	ip	Ib	Ik	I"k	ip	Ib	Ik
Bus8	0.800	12.788	26.267	12.514	17.632	36.216	17.632	17.632	10.998	22.591	10.998	10.998	22.795	46.822	22.795	22.795
Bus40	11.000	1.023	1.966	1.003	0.000	0.000	0.000	0.000	0.741	1.424	0.741	0.741	0.741	1.424	0.741	0.741
Bus70	11.000	0.875	1.507	0.873	0.000	0.000	0.000	0.000	0.560	0.965	0.560	0.560	0.560	0.965	0.560	0.560
Bus110	0.415	7.492	12.017	7.506	7.790	12.495	7.790	7.790	5.712	9.162	5.712	5.712	8.329	13.360	8.329	8.329
Bus113	0.800	13.275	27.548	13.018	17.241	35.777	17.241	17.241	10.873	22.562	10.873	10.873	22.709	47.123	22.709	22.709
MV_BUS	11.000	0.916	1.830	0.559	0.000	0.000	0.000	0.000	0.830	1.657	0.830	0.830	0.830	1.657	0.830	0.830

All fault currents are in rms kA. Current ip is calculated using Method C.

* LLG fault current is the larger of the two faulted line currents.

Project:

Location:

Contract:

Engineer:

Filename:

MINI-GRID (IMG) 6.45MWp/10MWh

JAJI, KADUNA

A. ADEFEMI

AES RENEWABLES

ETAP

24.0.1N

Study Case: SC

Page:

Date:

SN:

Revision:

Config.:

27

28-09-2026

DNDLYIR

Base

Normal

Sequence Impedance Summary Report

Bus		Positive Seq. Imp. (ohm)			Negative Seq. Imp. (ohm)			Zero Seq. Imp. (ohm)			Fault Zf (ohm)		
ID	kV	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance
Bus8	0.800	0.00565	0.06478	0.06503	0.00822	0.06220	0.06274	0.00191	0.00669	0.00695	0.00000	0.00000	0.00000
Bus40	11.000	1.67349	12.93703	13.04482	2.20788	12.39939	12.59443				0.00000	0.00000	0.00000
Bus70	11.000	4.08218	15.16960	15.70926	4.61657	14.63196	15.34298				0.00000	0.00000	0.00000
Bus110	0.415	0.02122	0.04419	0.04902	0.02202	0.04339	0.04866	0.01309	0.01963	0.02359	0.00000	0.00000	0.00000
Bus113	0.800	0.00424	0.06440	0.06454	0.00675	0.06189	0.06225	0.00059	0.00767	0.00769	0.00000	0.00000	0.00000
MV_BUS	11.000	0.77999	12.10919	12.13428	1.31440	11.57151	11.64592				0.00000	0.00000	0.00000

Project: MINI-GRID (IMG) 6.45MWp/10MWh
Location: JAJI, KADUNA
Contract:
Engineer: A. ADEFEMI
Filename: AES RENEWABLES

ETAP
24.0.1N

Study Case: SC

Page: 28
Date: 28-09-2026
SN: DNDLYIR
Revision: Base
Config.: Normal

Branch (earth-fault factor) Summary Report

Bus		EFF/Ke (LG)	EFF/Ke (LLG)
ID	kV		
Bus8	0.800	1.42	0.53
Bus40	11.000	1.65	2.21
Bus70	11.000	1.65	2.04
Bus110	0.415	1.02	0.87
Bus113	0.800	1.41	0.60
MV_BUS	11.000	1.65	2.29